

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7254-1501:115 Page 1 of 1

CATEGORY: Heat Detector (Single/Multi Station)

LISTEE: Edwards, 90 Fieldstone Court, Cheshire, CT 06410
Contact: Dave Mazur (203) 699-3155

DESIGN: Model 517FH single and multiple station, 135°F fixed temperature type heat detector. The unit is 120 VAC operated with a 9 VDC non-rechargeable battery backup. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as single/multiple station heat detector. This detector can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to listee's Installation Instructions Manual for details.

XLF: 7254-0569:125

08-11-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager